

**Action taken report of previous Dock Safety Committee Meeting
conducted on 29/06/2020:**

Sr.No.	Issues	Action taken report as on 28/09/2020
1.	Illumination level	<p>1. Berth No 1 to 10 and it's back up area having 71 nos high mast towers and 52 lattice towers.</p> <p>2. Berth no. 13 and it's back up area having 15 nos high mast towers</p> <p>3. Berth no.15 and it's back up area having 14 High mast towers.</p> <p>4. Oil jetty 3 High mast towers.</p> <p>5. North gate one and tunatkra one high mast towers were installed.</p> <p>All the above towers recently attended and rectified during rectification the following materials were consumed:</p> <p>a) 400 nos new 2x400 watts flood light fixtures</p> <p>b) 160 nos 1x1000 watts flood light fixtures.</p> <p>c) 250 nos 250 watts led flood light fixtures</p> <p>Apart from the to rectify the existing light fixtures,we used 350 chokes, 250 bulbs, 250 ignitors etc.</p> <p>At present, all the above towers were in working condition</p>
2.	Roads, warehouse and other infrastructures	<p>Road Repairing work at west gate-2 & 3 is under progress.</p> <p>Outside road from west gate-2 to berth NO.13 very poor condition.</p> <p>Warehouse demolition is under progress for 3 nos. of ware houses.</p> <p>Almost all office buildings of kandla is in poor condition. The heavy leakages in ceiling of all building and rain water ingresses in last rain.</p>
3.	Port entry pass of workers	<p>Currently manual entry pass is issued to workers. Once RFID implementation will completes online passes will be issued.</p> <p>Tender process for RFID and CCTV installation in port area under process.</p> <p>As per last board meeting, Instead of one tender for RFID and CCTV, it is to be split into two tenders.</p>
4.	Safety Audit	<p>Safety Audit for Oil Jetty is conducted from 31staug to 4th Sept 2020.</p>
5.	Safety Training	<p>Formation of "Institute for safety and productivity re-engineering is under progress".</p>

		Development of Container based training center at west gate-1 is under progress. It is predicted that center will be commissioned within a month time.
6.	Medical Examination of workers & First Aid Center:	Tender proposal for the development of occupational health center and first aider is pending with CMO.
7.	Condition of pipelines serving water to fire hydrants.	Repairing/replacement of fire hydrant line to be completed and hydro test to be conducted as it is pending.
8.	Structure Stability Test	Repairing work of berth No.7 has been started. Back filing work of the berth No.16 is under progress. Demolition work of total 3 nos. of old warehouses is under progress.
9.	Drinking water facility, latrines & urinals, spittoons, washing facilities, Shelters or Rest-sheds.	Drinking water tank has been installed at berth 13 to 16. Also, arrangement for refiling of the tank has been done. 21 locations inside the port area have been identified and portable water jars been supplied regularly. 16 nos. of office container is under procurement which will be supplied to traffic, custom, CISF and port users posted at gates, wharfs etc. There are no toilet blocks/urinals at berth No.13 to 16. Also there is no rest shelter/shed.
10.	Emergency Action Plan & Safety Report as per MSIHCR 1989	Safety Report preparation under progress and the report will be submitted within 1 month time period.
11.	Sign boards & Signage	Sign board installation work under progress by harbor division of civil department.
12.	Firefighting & Emergency Communication system	Work order for procurement of walky-talky is issued. Replacement of firefighting line is considered in Major revamping project of pipeline. Further estimate for the repairing work of firefighting is prepared.